



PROCEEDINGS OF THE COCHIN DEVASWOM BOARD

Abstract

Cochin Devaswom Board – Maramath wing- Providing AMC for the existing 62.5 KVA DG set of Sivasakthy building -Quotations invited –Order issued

- Read
1. Note from AE dt. 17-12-2024
 2. Note from AEE dt. 18-12-2024
 3. Note from EE dt. 18-12-2024
 4. Decision of DC dt. 26-12-2024

Order on H1. 2450/2024 dt. 03-01-2025

As per the papers cited above sanction is accorded to execute the above work after inviting local quotations as per the condition below.

- 1) The service provider should provide the uninterrupted working of the DG automatically according to the working of existing A.M.F
- 2) The service provider should visit the site frequently and take proper action for the automatic working of the DG with necessary labour if required.
- 3) The cost of parts, fuel, oil etc will be arranged departmentally as and when required for preventive maintenance, as per GST bill.
- 4) The service provider should ensure call on duty unlimitedly when required.
- 5) The service provider should provide service report at their own cost.
- 6) Proper working of Alternator /AVB should be ensured.

The sealed quotations should be received in this office on or before 16-01-2025 at 3 P.M. and will be opened at 3.30 P.M. on the same day in the presence of Executive Engineer, Cochin Devaswom Board/higher officials of Cochin Devaswom Board, Thrissur.

The sealed quotations should be addressed to the Executive Engineer, Cochin Devaswom Board, Thrissur and should contain the PAN number of the quotationer.

A copy of the estimate along with notification is herewith forwarded to Devaswom commissioner Devaswom Assistant Commissioner, Thrissur for exhibiting in their office Notice boards.

(By Order)
Sd/-
V.K. Ramakrishnan
Assistant Engineer (Electrical)

To
Notice Board,
The Assistant Commissioner, Thrissur,
The Executive Engineer ,
The Assistant Executive Engineer,
The Assistant Engineer , Stock File

//Approved for issue//
Bairh
For Junior Superintendent
(Senior clerk)