



PROCEEDINGS OF THE COCHIN DEVASWOM BOARD
Installation of Fire Hydrant System at Thiruvilwamala Vilwadrinathan temple.
Thiruvilwamala Devaswom – Thiruvilwamala Group.

- Read
1. Report of DAC Thiruvilwamala on M2. 1719/23 dt. 26-05-2023
 2. Note from AE dt. 4-11-2023
 3. Note from AEE dt. 8-11-2023
 4. Note from EE dt. 8-11-2023
 5. Decision of DC dt. 15-11-2023

Order on H1. 928/2023 dt. 26-12-2023

As per the papers cited above, sanction is accorded to execute the above work after inviting local quotations according to the specifications attached.

The sealed quotations should be received in this office on or before 09-01-2024 at 3 P.M. and will be opened at 3.30 P.M. on the same day in the presence of Executive Engineer, Cochin Devaswom Board/higher officials of Cochin Devaswom Board, Thrissur.

The sealed quotations should be addressed to the Executive Engineer, Cochin Devaswom Board, Thrissur and should contain the PAN number of the quotationer.

Notification along with specifications is herewith forwarded to Devaswom Assistant Commissioner, Thiruvilwamala for exhibiting in their office Notice board.

(By Order)
Sd/-
S. Gopakumar
Assistant Engineer

To

Notice Board, AC Thiruvilwamala,
CA to DC, EE, AEE, AE, S.F,

//Approved for issue//

Junior Superintendent

Specification

FIRE FIGHTING ARRANGEMENTS

A dry riser in 100 mm dia with all accessories like Hydrant valve, hose reel, hose box, Fire hose, pipe etc.

PIPE MS INDAL B CLASS 100 MM (APRX) 180M

PIPE MS INDAL B CLASS 25 MM (APRX48M)

HOSE REEL DRUM – 8 Nos.

HYDRUNT VALVE- 4 Nos.

HOSE BOX – 4 Nos.

BRANCH PIPE- 6 Nos.

FIRE HOSE – 4 Nos.

BALL VALVE - 8 Nos.